



Department of the Environment

A History of Power Plant Controls in Maryland

What Did We Learn? – Where do We go Next?



Part 2 - NO_x Issues






2014 NO_x RACT Requirement

- In 2014, MDE is required to update NO_x RACT (Reasonably Available Control Technology) requirements in the Maryland SIP (State Implementation Plan)
- RACT must be updated every time a new standard is adopted
- The current 75 ppb standard was adopted in 2008
- The updated NO_x RACT SIP is due on July 20, 2014
- This rulemaking process is intended to support that SIP submittal



Issues With NOx Emissions


- The new 75 ppb ozone standard requires us to focus on peak day NOx emissions
- Healthy Air Act (HAA) annual and “ozone season” caps have not forced units to always run emissions controls when they are needed
- Linked to lower capacity factors at many units
 - Coal units are simply not being asked to run as often as they used to run
- Some units also appear to not always be running their control equipment at a high level of efficiency to insure maximize emission reductions






Very Old Short-Term Emission Limits

- The HAA used ozone-season and annual caps to drive very significant emission reductions of NO_x
- The short-term limits for NO_x in Maryland regulations date back to the 1990s
 - For the new 75 ppb ozone standards, peak day NO_x emissions have become extremely important
 - Current short-term limits are clearly not appropriate for addressing peak day NO_x emissions
 - All short-term limits for all units will need to be updated



Decreasing Capacity Factors


- Capacity factor HAA Coal Fired Units



Capacity Factors of Maryland Coal plants have almost been reduced by 50%

Compliance with the HAA

- All of Maryland's power generators fully comply with the Maryland HAA of 2006
- The HAA used a regulatory scheme that allowed companies to choose where to control within their "system" to most cost-effectively meet the NOx and SO2 caps set in the Act.
 - Some units controlled more – some less
- The HAA set annual caps for SO2 and annual and ozone season caps for NOx
 - Short-term limits (hourly or daily) were not part of the HAA
 - Caps were set assuming that Maryland coal plants would continue to operate at pre-2006 levels



The HAA Worked Well


- The regulatory scheme in the HAA worked very well
 - Helped bring Maryland into attainment for the PM Fine standard and helped Maryland get very close to meeting the old 85 ppb ozone standard.
 - The HAA (2006) was designed for these older standards
- The new 1-hour SO₂ standard and the current 75 ppb ozone standard will require an enhanced regulatory scheme that focuses on:
 - Individual units and
 - Shorter term (hourly or daily) emission limits



NOx Emissions on Peak Ozone Days

Daily NOx Emissions By Plant

The table below shows the plant-by-plant, daily NOx emissions from Maryland coal units for the 7 worst ozone days in 2012






NOx Emissions on Peak Ozone Days

Daily NOx Emissions By Unit

The table below shows the units from Maryland coal units for



Dickerson and Chalk have single stacks for multiple units

Larger units with SCRs (Brandon Shores, Wagner 3, Morgantown and Chalk 1) are the lower peak day emitters

Smaller units without SCRs (Crane, Wagner 2, Chalk 2 and Dickerson) are the higher peak day emitters

Brandon Shores



H A Wagner



- Fort Smallwood Complex
 - Brandon Shores - Units 1 and 2
 - Wagner – Units 1, 2, 3 and 4
 - All on one contiguous property
- C.P. Crane – Units 1 and 2





Raven System Wide Compliance with MD HAA

HAA set annual and ozone season caps and allowed “system-wide” averaging
 With tougher ozone standard and focus on “peak days” – units that “under-controlled” are now being re-evaluated

	Brandon Shores Unit 1	Brandon Shores Unit 2	Crane Unit 1	Crane Unit 2	Wagner Unit 2	Wagner Unit 3	Total
2012 Annual NOx Tons	1,405	2,735	94			503	7,440
2012-On Annual NOx Limit, Tons	2,414	2,519	680	737	888	1,115	8,026
2012 Ozone NOx Tons	727					155	3,492
2012 Ozone NOx Limit, Tons			284	317	427	481	3,630

These two numbers show annual tons very close to annual limit

These two numbers show ozone season tons very close to the ozone season limit

Units with Red font use credits from units in Grey font to meet annual HAA Limit

- Built in 1984
- Boiler type - Brandon Shores 1 and 2 are both Babcock & Wilcox wall fired Units
- Installed 2 Selective Catalytic Reduction (SCR) control systems in 2002 (\$100M, and a cost of around 4% plant efficiency)
- Total capacity = 1,400 MW

Brandon Shores



Unit	Capacity (MW)	NO _x Controls	Old NO _x RACT (lb/mmBTU) 30-Day Rolling Average	HAA Limit* (Tons)	2012 Annual (Ozone) Average NO _x Emission Rate (lb/mmBTU)
Brandon 1 (Coal)	700	SCR	0.50	2,414	0.13 (0.09)
Brandon 2 (Coal)	700	SCR	0.50	2,519	0.22 (0.12)



Brandon Shores Unit 1

2010 to 2012 Data

Ozone Season Versus Non Ozone Season Operation


In Ozone Season the SCR is operated at high efficiencies to achieve Maximum NOx Reduction

In non Ozone Season the SCR is operated at lower efficiency - or not at all



Brandon Shores Unit 1 - 2012


Current Controls - SCR



MDE Current Thinking:
Allowable rate of 0.06 to
0.10 lb/mmBtu as a 24-
hour Rolling Average
(24hr RA)

Brandon Shores Unit 2 - 2012

Current Controls - SCR



MDE Current
Thinking: Allowable
rate of 0.08 to 0.11
lb/mmBtu (24hr RA)

- Continuous operation of the NO_x controls would have reduced 1,650 tons of NO_x emissions in 2012.
- Current thinking - 24 Hr Rolling Avg NO_x Emission Limit of 0.06 to 0.10 lb/mmBtu for Unit 1
- Current thinking - 24 Hr Rolling Avg NO_x Emission Limit 0.08 to 0.11 lb/mmBtu for Unit 2





Wagner Power Station


- Built in 1959 - 1972
- Boiler types
 - Units 2 and 3 are both coal burning Babcock & Wilcox wall fired unit units
 - Units 1 and 4 are Babcock & Wilcox Gas and Oil units
- Installed a SCR & SNCR control systems in 2003 & 2008 (\$55M)
- Total capacity = 1,400 MW



Unit	Capacity (MW)	NO _x Controls	Old NO _x RACT (lb/mmBTU) 30-Day Rolling Average	HAA Limit* (Tons)	2012 Annual (Ozone) Average NO _x Emission Rate (lb/mmBTU)
Wagner 2 (Coal)	136	SNCR	0.50	555	0.39 (0.43)
Wagner 3 (Coal)	359	SCR	0.50	1,115	0.13 (0.06)

Wagner Unit 3

Current Controls - SCR




Wagner 3 - Conclusion

- Operation of SCR at Wagner 3 similar to Brandon Shore SCR's.
- Continuous operation of controls could have reduced 213 tons of NO_x in 2012 at Wagner 3.
- MDE Current Thinking - 24 Hr Rolling Avg NO_x Emission Limit 0.05 to 0.06 lb/mmBtu.



Wagner 2


Current Controls - SNCR



Wagner 2 - SNCR In Operation

2010-2012 Wagner 2 - 24 Hr Avg Lb/mmBtu SNCR ON

avg NOx Lb/mmBtu




MDE Current Thinking: Allowable rate of 0.25 to 0.35 lb/mmBtu (24hr RA)

Some Operation of SNCR in Ozone Season 2011

No SNCR Operation in the Ozone Season 2012

Wagner 2 - SNCR Off

2010-2012 Wag Unit 2 - 24 Hr Rolling Avg NOx Lb/mmBtu SNCR off



Wagner 2 - Conclusions

- The SNCR on Unit 2 ran 28% of time it could have run.
- The SNCR did not run in the ozone season of 2012 at all.
- Continuous operation of controls could have reduced 198 tons of NO_x in 2012 at Wagner 2.
- Current thinking - 24 Hr Rolling Avg NO_x Emission Limit between 0.25 and 0.35 lb/mmBtu.





Raven Power – C.P. Crane


- Built in 1963
- Boiler types
 - Units 1 and 2 are both coal burning cyclone units - Babcock and Wilcox Boilers
- Installed SNCRs in 2009 (\$12 M)
- Total capacity = 400 MW




Unit	Capacity (MW)	NO _x Controls	Old NO _x RACT (lb/mmBTU) 30-Day Rolling Average	HAA Limit* (Tons)	2012 Annual (Ozone) Average NO _x Emission Rate (lb/mmBTU)
CP Crane 1 (Coal)	200	SNCR	0.70	686	0.400 (0.411)
CP Crane 2 (Coal)	200	SNCR	0.70	737	0.357 (0.410)

Capacity Factors at Crane

- Dramatic reductions since 2001 to 2007 timeframe
- Units are simply not being called upon to run as much as they used to be called upon




NOx Emissions on Peak Ozone Days






Crane Unit 1 – SNCR On



MDE Current Thinking: Allowable rate of 0.25 to 0.35 lb/mmBtu (24hr RA)



Crane Unit 1 – SNCR Off






Crane Unit 2 – SNCR On

2010-2012 24 Hr Avg NOx Lbs/mmBtu

Mixture of coal used in this area that doesn't represent current operation




MDE Current Thinking: Allowable rate of 0.25 to 0.35 lb/mmBtu (24hr RA)





Crane Unit 2 – SNCR Off

2010-2012 Data -24 Hr Avg NOx Lb/mmBtu



Deeper Reductions at Crane

- MDE is researching a hybrid SCR/SNCR technology that appears to be well suited for both Crane units
- Appears to significantly reduce NOx
 - 0.08 to 0.11 lb/mmBtu
- Very cost effectively
 - \$2000 to \$3000 per ton
- Operational by 2015 to support Moderate area attainment needs



C.P. Crane – Conclusions

- SNCR operation
 - Unit 1 SNCR ran 14% of time it could have.
 - Unit 2 SNCR ran 33% of time it could have.
- Through 2015
 - Current thinking – Unit 1
 - Through 2015 - 24 Hr Rolling Average NOx Emission Limit of 0.25 to 0.35 lb/mmBtu.
 - Current thinking – Unit 2
 - Through 2015 - 24 Hr Rolling Average NOx Emission Limit of 0.25 to 0.35 lb/mmBtu
- By 2015
 - Current thinking - Both Units
 - 24 Hr Rolling Average NOx Emission Limit of 0.08 to 0.11 lb/mmBtu





Raven Power – Current MDE Thinking

Short-Term NOx Limits

Coal Fired Units	Old NOx RACT	MDE Current Thinking Updated NOx RACT
Brandon Unit 1 (SCR)	0.50 lb/mmBTU 30 Day Rolling Average	0.06 to 0.10 lb/mmBTU 24-hr Rolling Average
Brandon Unit 2 (SCR)	0.50 lb/mmBTU 30 Day Rolling Average	0.08 to 0.11 lb/mmBTU 24-hr Rolling Average
Wagner Unit 2 (SNCR)	0.50 lb/mmBTU 30 Day Rolling Average	0.25 to 0.35 lb/mmBTU 24-hr Rolling Average
Wagner Unit 3 (SCR)	0.50 lb/mmBTU 30 Day Rolling Average	0.05 to 0.06 lb/mmBTU 24-hr Rolling Average
Crane Unit 1 (SNCR)	0.70 summer/1.50 winter Lb/mm Btu 30 Day Rolling Average	0.25 to 0.35 lb/mmBTU 24-hr Rolling Average By 2015 – 0.08 to 0.11 lb/mmBtu 24-hr Rolling Average
Crane Unit 2 (SNCR)	0.70 summer/1.50 winter Lb/mm Btu 30 Day Rolling Average	0.25 to 0.35 lb/mmBTU 24-hr Rolling Average By 2015 – 0.08 to 0.11 lb/mmBtu 24-hr Rolling Average


Nuclear



- Morgantown - Units 1 and 2
- Dickerson – Units 1, 2 and 3
- Chalk Point – Units 1 and 2

Compliance with the HAA

- All of Maryland's power generators fully comply with the Maryland Healthy Air Act (HAA)
- The HAA used a regulatory scheme that allowed companies to choose where to control within their "system" to most cost-effectively meet the NO_x and SO₂ caps set in the Act.
 - Some units controlled more – some less
- The HAA set annual caps for SO₂ and annual and ozone season caps for NO_x
 - Short-term limits (hourly or daily) were not part of the HAA
 - Caps were set assuming that Maryland coal plants would continue to operate at pre-2006 levels



The HAA Worked Well

- The regulatory scheme in the HAA worked very well
 - Helped bring Maryland into attainment for the PM Fine standard and helped Maryland get very close to meeting the old 85 ppb ozone standard.
 - The HAA (2006) was designed for these older standards
- The new 1-hour SO₂ standard and the current 75 ppb ozone standard will require an enhanced regulatory scheme that focuses on:
 - Individual units and
 - Shorter term (hourly or daily) emission limits





NRG System Wide Compliance with the HAA

HAA set annual and ozone season caps and allowed “system-wide averaging
With tougher ozone standard and focus on “peak days” – units
that “under” evaluated

	Morgantown Unit 1	Morgantown Unit 2	Morgantown Unit 3	Morgantown Unit 4	Dickerson Units 1, 2 & 3	Total
2012 Annual NOx Tons	343	458	544	1,728	1,740	4,581
2012-On Annual NOx	2,094	2,079	1,166	1,223	1,736	8,098
		195	98	828	761	2,034
2012-On Ozone NOx Limit, Tons	868	864	503	542	760	3,567

These two numbers show Annual tons emitted well under annual limit

Units with Red font use credits from units in Grey font to meet annual HAA Limit

These two numbers show Ozone Season tons emitted well under Ozone Season limit





NRG – Morgantown

- Built in 1967
- Boiler types
 - Units 1 And 2 are both coal burning T-fired units - manufactured by Alstom
- Installed SCR control systems in 2007 and 2008 (about \$120M)
- Total capacity = 1,280 MW




Unit	Capacity (MW)	NO _x Controls	Old NO _x RACT 30-Day Rolling Average (lb/mmBTU)	HAA Facility Allowance (Tons)	2012 Average NO _x Emission Rate (lb/mmBTU)
Morgantown Unit #1 Tangentially Coal Fired	640	Low NO _x Burners, Over Fired Air, and SCR	0.70	Annual - 2,094 Ozone - 1,053	Annual - 0.032 Ozone - 0.032
Morgantown Unit #2 Tangentially Coal Fired	640	Low NO _x Burners, Over Fired Air, and SCR	0.70	Annual - 2,079 Ozone - 1,048	Annual - 0.031 Ozone - 0.030



Morgantown Unit 1


Current Controls - SCR



Morgantown Unit 2

Current Controls - SCR

2012 NRG Morgantown Unit #2



Morgantown - Conclusions

- Both units experience excellent operation and run controls all year long
- Current thinking - 24 Hr Rolling Avg NOx Emission Limit of 0.05 to 0.08 lb/mmBtu for Unit 1
- Current thinking - 24 Hr Rolling Avg NOx Emission Limit 0.06 to 0.10 lb/mmBtu for Unit 2





Chalk Point

- Built in 1964, Boiler types:
 - Units 1 and 2 are both coal burning Combustion Engineering Wall fired units
 - Units 3 and 4 are oil fired
- Installed a SCR control system on Unit 1 in 2008 (\$60M) and a SACR control system on Unit 2 in 2006 (\$20M)
- Total capacity = 2000 MW




Unit	Capacity (MW)	NO _x Controls	Old NO _x RACT 30-Day Rolling Ave. (lb/mmBTU)	HAA Facility Allowance (Tons)	2012 Ave. NO _x Emission Rate (lb/mmBTU)
Chalk Point Unit #1 Wall Fired Fuel: Coal	355	Low NO _x Burners, Over Fired Air, and SCR	0.80	Annual – 1,166 Ozone - 611	Annual – 0.063 Ozone - 0.068
Chalk Point Unit #2 Wall Fired Fuel: Coal	355	Low NO _x Burners, Over Fired Air, and SACR	0.80	Annual – 1,223 Ozone - 657	Annual – 0.368 Ozone - 0.343
Combined Stack (Both Units 1 & 2)	710	As listed above	0.80	Annual – 2,389 Ozone - 1,268	Annual – 0.229 Ozone - 0.201

NOx Emissions on Peak Ozone Days

The table below shows coal unit emissions from Maryland on peak ozone days in 2012


Chalk Point emissions - 14 tons per day (80% from SACR)





Chalk Point - 2012

Current Controls – SCR on Unit 1 – SACR on Unit 2
Both Units discharge through a common stack





Deeper Reductions at Chalk Point 2

- In filings with the U.S. Securities and Exchange Commission, GenOn Energy (now NRG) discussed plans to add SCR control technology at Chalk Point Unit 2 by the 2018 to 2021 timeframe
- Because of Maryland's severe ozone nonattainment problems, MDE believes these controls need to be implemented in a timeframe consistent with the CAA's attainment deadlines
- SCRs at Chalk Point 2 would significantly reduce NOx
 - 0.08 to 0.10 lb/mmBtu
- Operational by 2015 to support Moderate area attainment needs



Chalk Point - Conclusions

- SACR Selective Auto Catalytic system on Unit 2 much less efficient than SCR on Unit 1
 - Results in high peak day NOx emissions
- Current thinking:
 - Through 2015 - 24 Hr Rolling Average NOx Emission Limit of 0.10 to 0.15 lb/mmBtu for combined stack.
 - By 2015 - 24 Hr Rolling Average NOx Emission Limit of 0.08 to 0.10 lb/mmBtu for combined stack.





NRG - Dickerson

- Built in 1960
- Boiler types
 - Units 1,2, & 3 are both coal burning Combustion Engineering T-fired units
- Installed a SNCR control systems in 2009 (\$15M)
- Total capacity = 570 MW




Unit	Capacity (MW)	NOx Controls	Old NO _x RACT 30-Day Rolling Ave. (lb/mmBTU)	HAA Facility Allowance (Tons)	2012 Ave. NO _x Emission Rate (lb/mmBTU)
Dickerson #1 T Fired Fuel: Coal	190	LNCFS III, and SNCR	0.80	Annual – 554 Ozone - 257	Annual – 0.26 Ozone - 0.26
Dickerson #2 T Fired Fuel: Coal	190	LNCFS III, and SNCR	0.80	Annual – 607 Ozone - 274	Annual – 0.26 Ozone - 0.26
Dickerson #3 T Fired Fuel: Coal	190	LNCFS III, and SNCR	0.80	Annual – 575 Ozone - 259	Annual – 0.25 Ozone - 0.26
Combined Stack: Units 1, 2, & 3	570	As listed above	0.80	Annual – 1,736 Ozone - 790	Annual – 0.26 Ozone - 0.26



NOx Emissions on Peak Ozone Days


The table below shows the unit-by-unit, daily NOx emissions from Maryland coal units for the 7 worst ozone days in 2012





Dickerson Units 1 2 & 3 - 2012

Current Controls - SNCR




Deeper Reductions at Dickerson

- In filings with the U.S. Securities and Exchange Commission, GenOn Energy (now NRG) discussed plans to add SCR control technology at Dickerson by the 2018 to 2021 timeframe
- Because of Maryland's severe ozone nonattainment problems, MDE believes these controls need to be implemented in a timeframe consistent with the CAA's attainment deadlines
- SCRs at Dickerson would significantly reduce NO_x
 - 0.08 to 0.10 lb/mmBtu
- Operational by 2015 to support Moderate area attainment needs



Dickerson – Conclusions

- Dickerson has not ran SNCR since 2009
- 2009 testing of SNCR showed a 15 -20% drop in NOx Rate
- Capacity factor significantly decreased at Dickerson
- Current thinking
 - Through 2015 - 24 Hr Rolling Avg NOx Emission Limit of 0.15 to 0.20 lb/mmBtu
 - By 2015 - 24 Hr Rolling Avg NOx Emission Limit of 0.08 to 0.10 lb/mmBtu





NRG – Current MDE Thinking

Short-Term NO_x Limits

Coal Fired Units	Old NO_x RACT	MDE Current Thinking Updated NO_x RACT
Chalk Point 1 & 2 Common Stack (SCR & SACR)	0.80 lb/mmBtu 30 Day Rolling Average	0.1 to 0.15 lb/mmBtu 24-hr Rolling Average By 2015 – 0.08 to 0.10 lb/mmBtu 24-hr Rolling Average
Morgantown 1 (SCR)	0.70 lb/mmBtu 30 Day Rolling Average	0.05 to 0.08 lb/mmBtu 24-hr Rolling Average
Morgantown 2 (SCR)	0.70 lb/mmBtu 30 Day Rolling Average	0.06 to 0.10 lb/mmBtu 24-hr Rolling Average
Dickerson 1,2 & 3 Common Stack (SNCR)	0.70 Lb/mm Btu 30 Day Rolling Average	0.2 to 0.25 lb/mmBtu 24-hr Rolling Average By 2015 – 0.08 to 0.10 lb/mmBtu 24-hr Rolling Average

AES Warrior Run

- Built in 2000
- Boiler types
 - ABB Combustion Engineering coal fired circulating fluidized bed (ACFB)
 - Well controlled by inherently low emitting design of fluidized bed boiler.
- Total capacity = 205 MW




Unit	Capacity (MW)	NOx Controls	NOx RACT 30-Day Rolling Average (lb/mmBTU)	HAA Facility Allowance (Tons)	2012 Average NOx Emission Rate (lb/mmBTU)
Warrior Run #1 Fluid Bed Fuel: Coal	290	SNCR	n/a	n/a	Annual – 0.08 Ozone - 0.07



AES Warrior Run - 2013

NOx Rate Lb/mm Btu Calculated



AES Warrior Run – Conclusions

- Very low rates accomplished with inherently low emitting design of the fluidized bed boiler
- Warrior Run is not included in HAA
- SNCR is not operated
- Current thinking - 24 Hr Rolling Average NO_x Emission Limit – 0.05 to 0.09 lb/mmBtu



Alternative NO_x RACT Concept

... being considered

- Averaging within a system for NO_x and ozone makes sense if averaging results in peak day reductions equal to or greater than the reductions from unit-by-unit limits
- MDE is continuing to analyze an option that may provide flexibility while achieving equal or greater reductions
- Current thinking – Alternative RACT:
 - System-wide average rate of 0.10 lb/mmBtu as a 24-hour rolling, and
 - System-wide average rate of 0.08 lb/mmBtu as a 30-day rolling average



Next Steps - NOx

- Continue to analyze hybrid SCR/SNCR system at Crane
- Continue to analyze SCR controls at Chalk Point and Dickerson
- Continue to analyze system-wide alternative RACT
- Continue to work with EPA on start-up/shut-down issues
- Continue to work with stakeholders on proposed limits
- Suggest that December meeting focus solely on NOx RACT limits

